



- RJ45:
- 1 GND
- 2 GND
- 3 CS-
- 4 CS+
- 5 VS-
- 6 VS+
- 7
- 8

Standard: IEC 60044-7, 60044-8
 Isolation level: VS 24/50/125kV, CS 0,72kV
 Temperature range: -5/40°C
 Accuracy class: VS C11 & 3P
 Secondary output: VS 10000/1V; VC 1000A/31mV
 Burden: VS 1MΩ ±2%; <50pF, CS 10kΩ ±2%; <10pF
 Thermal short time time I_{th}: 16kA
 Harmonics: 1th & 2th Amplitude 1%, Phase 1°/ 3th - 50th Amplitude 5%, Phase 5°
 Correctionfactor: ± 30% for amplitude error, 180° for phase error
 Bending force on request

Accuracy class: CS		
I _p	Amplitude	Phase
1%	± 5	± 2
5%	± 1	± 2
100%	± 1	± 2
20000%	± 5	± 2

Dept. GWP	Technical reference K240P	Created by W. Bacher 21.09.2018	Approved by N. Juschicz 21.09.2018
		Document type Drawing	Document status Draft
		Title Indoor sensor V&C combined X5400/1	
A3/1:3		DWG No. K240S-4E	
Rev. 1	Date of issue 21.09.2018	Sheet 1/1	