


Standard: IEC 60044-7
 Isolation level: 24/50/125kV
 Temperature range: -5/40°C
 Accuracy class: C11 & 3P
 Secondary output: 10000/1V
 Harmonics: 1th &2th Amplitude 1%, Phase 1°/ 3th - 50th Amplitude 5%, Phase 5°
 Correctionfactor: ± 30% for amplitude error, 180° for phase error
 Bending force on request

Dept. GWP	Technical reference T240L	Created by W. Bacher 20.09.2018	Approved by N. Juschicz 20.09.2017
 A3/1:2	Document type Drawing	Document status Draft	
	Title Indoor Smartgrid V measurement X5400/2	DWG No. T240S-4E	
		Rev. 1	Date of issue 20.09.2017